

1600 South Second Street Mount Vernon, WA 98273-5202 ph 360.428.1617 fax 360.428.1620 www.nwcleanair.org

Air Operating Permit Excess Emissions Report Form Part II

Name of Facility	Shell, Puget Sound Refinery		Reported by		Tim Figgie
Date of notification	July 11, 2012		Incident type: breakdown/ upset/startup or shutdown		breakdown
Start Date	July 11, 2012		Start Time:		11:00 AM
End Date	July 11, 2012		End Time:		12:00 noon
Process unit or system(s): Cogen #2					
Incident Description					
Immediate steps taken to limit the duration and/or quantity of excess emissions:					
The unit was restarted as soon as practicable.					
Applicable air operating permit term(s): 5.9					
		Pollutant(s): CO		Pounds (Estimate): 2	
The incident was the result of the following (check all that apply): Scheduled equipment startup Scheduled equipment shutdown Poor or inadequate design Careless, poor, or inadequate operation Poor or inadequate maintenance A reasonably preventable condition Did the facility receive any complaints from the public? No Yes (provide details below)					
Did the incident result in the violation of an ambient air quality standard No Yes (provide details below) Root and other contributing causes of incident: The root cause of this event was a faulty fuel gas supply valve switch.					
The root cause of the incident was:					

(The retention of records of all required monitoring data and support information shall be kept for a period of five years from the date of the report as per the WAC regulation (173-401-615))

☑ Identified for the first time

The root cause of this event was a faulty fuel gas supply valve switch. recurrence (explain previous incident(s) below – provide dates)

Identified as a

Page 2 The root cause of this event was a faulty fuel gas supply valve switch. Are the emissions from the incident exempted by the NSPS or NESHAP "malfunction" definitions below? No X Yes (describe below) The root cause of this event was a faulty fuel gas supply valve switch. Definition of NSPS "Malfunction": Any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or failure of a process to operate in a normal or usual manner. Failures that are caused in part by poor maintenance or careless operation are not malfunctions. 40 CFR 60.2 <u>Definition of NESHAP "Malfunction"</u>: Any sudden, infrequent, and not reasonably preventable failure of air pollution control and monitoring equipment, process equipment, or a process to operate in a normal or usual manner which causes, or has the potential to cause, the emission limitations in an applicable standard to be exceeded. Failures that are caused in part by poor maintenance or careless operation are not malfunctions. 40 CFR 63.2 Analyses of measures available to reduce likelihood of recurrence (evaluate possible design, operational, and maintenance changes; discuss alternatives, probable effectiveness, and cost; determine if an outside consultant should be retained to assist with analyses): The faulty fuel gas supply valve switch was replaced. Description of corrective action to be taken (include commencement and completion dates): See above If correction not required, explain basis for conclusion: See above Attach Reports, Reference Documents, and Other Backup Material as Necessary. This report satisfies the requirements of both NWCAA regulation 340, 341, 342 and the WAC regulation (173-400-107). Is the investigation continuing? ⊠No ∐Yes Is the source requesting additional time for completion of the report? \square No \square Yes Based upon information and belief formed after reasonable inquiry, I certify that the statements and information in this document and all referenced documents and attachments are true, accurate and complete. Prepared By: _ Ken Long__ Date: ___ July 11, 2012 Date: 7/24/12

Air Operating Permit

Excess Emissions Report Form Part II

Responsible Official or Designee: